

3rd Quarter 2021 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	ND ⁽¹⁾	ND	ND	ND	ND	ND	ND	Treatment in Place
<u>Rockaway Avenue Site</u>								
Well No. 8	1.0	4.6	5.1	ND	ND	ND	2.0	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
<u>Wilson Street Site</u>								
Well No. 9	0.42	2.2	ND	ND	ND	ND	4.1	
<u>Clinton Road Site</u>								
Well No. 10	ND ⁽²⁾	ND	ND	ND	ND	ND	ND	Treatment in Place
Well No. 11	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	Treatment in Place
<u>Country Club Site</u>								
Well No. 13	0.85	10.8	5.0	ND	2.2	3.6	16.0	
Well No. 14	N/A	21.6	9.8	ND	6.6	6.9	15.0	Out of Service in 3rd Quarter
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021

** There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

(1) Two samples were taken during quarter as follows (ND, ND)

(2) Four samples were taken during quarter as follows (ND, ND, ND, ND)

Legend:

PFOA:	Perfluorooctanoic acid	**PFHxS:	Perfluorohexanesulfonic acid	ppb:	parts per billion
PFOS:	Perfluorooctanesulfonic acid	**PFNA:	Perfluorononanoic acid	ppt:	parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL:	Maximum Contaminant Level	ND:	Sample result was below detectable limit
**PFHpA:	Perfluoroheptanoic acid				