

4th Quarter 2021 Sampling Results for Emerging Contaminants

Plant/Well	1,4-Dioxane (ppb)	PFOS (ppt)	PFOA (ppt)	PFBS** (ppt)	PFHpA** (ppt)	PFHxS** (ppt)	PFNA** (ppt)	Comments
<u>Waterworks Site</u>								
Well No. 7	ND ⁽¹⁾	ND	ND	ND	ND	ND	ND	Treatment in Place
<u>Rockaway Avenue Site</u>								
Well No. 8	1.1	4.5	5.7	ND	ND	ND	2.1	
Well No. 12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
<u>Wilson Street Site</u>								
Well No. 9	0.39	2.5	ND	ND	ND	ND	4	
<u>Clinton Road Site</u>								
Well No. 10	ND ⁽²⁾	ND ⁽²⁾	ND ⁽²⁾	ND ⁽²⁾	ND ⁽²⁾	ND ⁽²⁾	ND ⁽²⁾	Treatment in Place
Well No. 11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 4th Quarter
<u>Country Club Site</u>								
Well No. 13	0.75	12.5	5.6	ND	2.6	4.6	18.9	
Well No. 14	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 4th Quarter
<u>Hilton Park Site</u>								
Well No. 15	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021
Well No. 16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Out of Service in 2021

** There is no maximum contaminant level associated with these additional compounds as they are currently not regulated.

⁽¹⁾ Two samples were taken during quarter as follows (ND, ND), Lab analysis for a third sample taken on 12/27 has not been completed.

⁽²⁾ Two samples were taken during quarter as follows (ND, ND), Well No. 10 out of Service in December.

Legend:

PFOA:	Perfluoroctanoic acid	**PFHxS: Perfluorohexanesulfonic acid	ppb: parts per billion
PFOS:	Perfluoroctanesulfonic acid	**PFNA: Perfluorononanoic acid	ppt: parts per trillion
**PFBS:	Perfluorobutanesulfonic acid	MCL: Maximum Contaminant Level	ND: Sample result was below detectable limit
**PFHpA:	Perfluorooctane sulfonic acid		